



City of Concord, New Hampshire

PURCHASING DIVISION

COMBINED OPERATIONS & MAINTENANCE FACILITY

311 NORTH STATE STREET

CONCORD, NH 03301

(603) 230-3664 FAX: (603) 230-3656

www.concordnh.gov/Purchasing

September 1, 2011

ADDENDUM NUMBER TWO

B03-12

MANCHESTER STREET ROADWAY & SIGNALIZATION IMPROVEMENTS

TO ALL FIRMS OF RECORD: This addendum forms a part of and modifies the bidding and contract documents and technical specifications for the project named above. The following changes, additions and clarifications are made to the original Contract Documents:

1. **Question:** Is all the asphalt that has to be removed or reclaimed included in either item 203.1 or item 306.11?

Answer: Yes, all asphalt that needs to be removed should be included in item 203.1. All asphalt to be reclaimed is included in item 306.11.

2. **Question:** Existing CB that are having the grates changed to rim/cover, need to have brick inverts constructed as well?

Answer: No. CBs that will have their grates changed to rim/cover will not need to have brick inverts constructed as the existing sump will remain. The rim/cover will need to be adjusted to final grade which is subsidiary to item 604.6.

PLEASE BE ADVISED THAT THE CONTRACTOR MUST ACKNOWLEDGE RECEIPT OF ADDENDUM ONE AND TWO AS PART OF THE CONTRACTOR'S BID SUBMISSION (PAGE 00301-9).

CITY OF CONCORD, NEW HAMPSHIRE

DOUGLAS B. ROSS
PURCHASING MANAGER