



City of Concord, New Hampshire

PURCHASING DIVISION

COMBINED OPERATIONS & MAINTENANCE FACILITY

311 NORTH STATE STREET

CONCORD, NH 03301

(603) 230-3664 FAX: (603) 230-3656

www.concordnh.gov/Purchasing

February 1, 2012

ADDENDUM NUMBER ONE

B13-12

HALL STREET AND PENACOOK WASTEWATER TREATMENT PLANTS SCADA PHASE II-B UPGRADE

TO ALL FIRMS OF RECORD: This addendum forms a part of and modifies the bidding and contract documents and technical specifications for the project named above. The following changes, additions and clarifications are made to the original Contract Documents:

- 1. Pre-Bid Meeting Sign-In Sheet.** A copy of the sign-in sheet from the non-mandatory pre-bid meeting held on January 26, 2012 at 10:00 am is attached for your review and records.
- 2. Bidder's Submission Checklist, Page A-5.1.** Please delete the requirement to submit a Specifications Exception Form as part of each Contractor's bid.
- 3. Information for Bidders, Page A-2.1.** Please change the 4th sentence in the last paragraph on this page to read: "No BIDDER may withdraw a BID within **ninety (90) calendar days** after the actual date of the opening thereof."
- 4. Purchasing Division Office Location.** Please note that the address for the Purchasing Division Office is incorrect in several locations throughout B13-12. The correct address, and the location to which each Contractor's bid must be delivered no later than 2:00 pm on February 14, 2012, is: City of Concord, Purchasing Division, Combined Operations & Maintenance Facility, 311 North State Street, Concord, NH 03301.
- 5. Section 01110, Summary of Work, Section 1.31.** Please add the following to the first paragraph:
"One Utility Water pump shall remain operational at all times. The Contractor shall coordinate with the Owner to schedule power tie-ins and instrumentation cut-over in advance. The Contractor shall upgrade the utility water pumps one unit at a time and work shall not commence on the second unit until testing and startup of the first unit is completed. One intermediate pump station flow meter shall remain operational at all times. The Contractor shall upgrade the flow meters one unit at a time and work shall not commence on the second unit until testing and startup of the first unit is completed."

6. **Section 13610, Control System, Part 1.1.** Please replace the first paragraph with the following:

“The Work shall include (but not be limited to) modifications of existing control panels as shown on the Drawings, and installation of new control panels as shown on the Drawings. The Control Panel Drawings are as follows:

I-A01	Legend and Notes
I-A02	CP-15 Bill of Materials
I-A03	CP-15 Equipment Layout
I-A04	CP-15 Power Distribution
I-A05	Panel CP-15 Slot 1
I-A06	Panel CP-15 Slot 2
I-A07	Panel CP-15 Slot 4
I-A08	Panel CP-15 Slot 5
I-A09	Panel CP-15 Slot 6
I-A10	CP-15 Network Diagram
I-A11	CP-15A Panel Layout
I-A12	CP-15A Bill of Materials
I-A13	CP-15A Wiring Diagram
I-A14	CP-15A Slot 7 & Slot 8
I-A15	CP-15A Slot 9 & Slot 10
I-A16	CP-15A Slot 11 & Slot 12
I-C01	CP-1 Bill of Materials
I-C02	CP-1 Panel Layout
I-C03	CP-1 Power Distribution
I-C04	CP-1 I/O Points
I-C05	CP-1 I/O Points Continued
I-C06	CP-1 I/O Points Continued
I-D01	CP-2 Bill of Materials
I-D02	CP-2 Panel Layout
I-D03	CP-2 Power Distribution
I-D04	CP-2 I/O Points
I-D05	CP-2 I/O Points Continued
I-D06	CP-2 I/O Points Continued
I-D07	CP-2 I/O Points Continued
I-D08	CP-2 I/O Points Continued
I-D09	CP-2 I/O Points Continued
I-E01	Panel MCP-1 Bill of Materials
I-E02	Panel MCP-1 Panel Layout
I-E03	Panel MCP-1 Power Distribution
I-E04	Panel MCP-1 Digital Inputs
I-E05	Panel MCP-1 Relay Outputs”

7. **Drawing E-10.** Please remove drawing E-10 from your bid package and replace it with the drawing E-10 included with this Addendum. Changes to this drawing are showing the VFD wiring referencing the Toshiba packaged drives purchased by the Owner for this project.

8. **Drawing E-12.** Please remove drawing E-12 from your bid package and replace it with the drawing E-12 included with this Addendum. Changes to this drawing include clarification to the details of the phone line for the autodialer.

PLEASE BE ADVISED THAT THE CONTRACTOR MUST ACKNOWLEDGE RECEIPT OF ADDENDUM ONE ON PAGE A-3.1 OF THE BID.

CITY OF CONCORD, NEW HAMPSHIRE



DOUGLAS B. ROSS
PURCHASING MANAGER

