



# City of Concord, New Hampshire

## PURCHASING DIVISION

COMBINED OPERATIONS & MAINTENANCE FACILITY

311 NORTH STATE STREET

CONCORD, NH 03301

(603) 225-8530

FAX: (603) 230-3656

[www.concordnh.gov](http://www.concordnh.gov)

June 4, 2010

### ADDENDUM NUMBER THREE

B42-10

### CRESCENT STREET RECONSTRUCTION PROJECT

TO ALL FIRMS OF RECORD: This addendum forms a part of and modifies the bidding and contract documents and technical specifications for the project named above. The following changes, additions and clarifications are made to the original Contract Documents:

- Revisions to Bid Form
  1. Change bid item number 543.3 to 534.3 on page 25. Description of item remains the same.
  2. Change bid item 608.26 to bid item 608.36 on page 26 and change description to 6" Reinforced Concrete Sidewalk (F).
- Questions were received from bidders as to whether PVC pipe would be allowed as a substitution for the specified RCP drainage pipe. The answer is that a substitution for the specified product will NOT be allowed.

PLEASE BE ADVISED THAT THE CONTRACTOR MUST ACKNOWLEDGE RECEIPT OF ADDENDUM THREE ON THE BID SHEET SIGNATURE PAGE (PAGE 29).

CITY OF CONCORD, NEW HAMPSHIRE

DOUGLAS B. ROSS  
PURCHASING MANAGER