



City of Concord, New Hampshire

PURCHASING DIVISION

COMBINED OPERATIONS & MAINTENANCE FACILITY

311 NORTH STATE STREET

CONCORD, NH 03301

(603) 225-8530

FAX: (603) 230-3656

www.concordnh.gov

May 6, 2010

ADDENDUM NUMBER TWO

RFP36-10

INSPECTION AND CLEANING OF FIVE CONCRETE WATER STORAGE TANKS IN A FIVE YEAR ROTATION

TO ALL FIRMS OF RECORD: This addendum forms a part of and modifies the proposal and contract documents and technical specifications for the project named above. The following additions, changes and clarifications are made to the original proposal documents:

- 1) **Question:** What was the average depth of the sediment in each tank at the last cleaning?

Answer: There was a uniform layer of accumulated precipitate found on all floor surfaces averaging 1/8" in depth.

PLEASE BE ADVISED THAT THE PROPOSER MUST ACKNOWLEDGE RECEIPT OF ADDENDUM ONE AND TWO ON THE PROPOSAL SHEET SIGNATURE PAGE.

CITY OF CONCORD, NEW HAMPSHIRE

DOUGLAS B. ROSS
PURCHASING MANAGER