



City of Concord, New Hampshire

PURCHASING DIVISION

COMBINED OPERATIONS & MAINTENANCE FACILITY

311 NORTH STATE STREET

CONCORD, NH 03301

(603) 230-3664 FAX: (603) 230-3656

www.concordnh.gov/Purchasing

April 18, 2012

ADDENDUM NUMBER TWO

RFP22-12

REGENERATION OF GRANULAR ACTIVATED CARBON OR REPLACEMENT OF GRANULAR ACTIVATED CARBON WITH VIRGIN GRANULAR ACTIVATED CARBON FOR TASTE AND ODOR CONTROL WATER TREATMENT PLANT

TO ALL FIRMS OF RECORD: This addendum forms a part of and modifies the bidding and contract documents and technical specifications for the project named above. The following changes, additions and clarifications are made to the original Contract Documents:

1. **Question:** We need to know is the activated carbon in open bay filters or pressure filters?

Answer: Open bay filters.

2. **Question:** To remove the spent GAC can we use a vacuum truck or do we need a slurry truck?

Answer: Vacuum truck.

PLEASE BE ADVISED THAT THE PROPOSER MUST ACKNOWLEDGE RECEIPT OF ADDENDUM ONE AND TWO ON THE PROPOSAL SHEET SIGNATURE PAGE (PAGE 13226-24).

CITY OF CONCORD, NEW HAMPSHIRE

DOUGLAS B. ROSS
PURCHASING MANAGER